

1. **Kenncode des Produkttyps:** Fire PROtec EI 60 Sa S200 MARC - SN: xx
2. **Verwendungszweck:** Selbstschließend, rauchdichter und textil raumabschließender Feuerschutzabschluss mit isolierender Wirkung für Laibungs- und Wandmontage
3. **Hersteller:** SIMON PROtec Systems GmbH
 Herstelleradresse: Medienstraße 8
 D-94036 Passau
 Germany
4. **System der Leistungsbeständigkeit:** System 1 | System 3
5. **Notifizierte Stelle:** CTO S.A.
Nummer der notifizierten Stelle: 2434
Nr. der Leistungsbeständigkeit: 2434-CPR-0110
Harmonisierte Produktnorm: EN 16034:2014 | EN 13241:2003+A2:2016
6. **Leistungserklärung:**

Wesentliche Merkmale:	Leistung:
max. lichte Öffnung	18000 x 10000 mm*
	EN 16034:2014
Feuerwiderstand	EI ₂ 60 EW 120
Smoke Control	Sa S200*
Fähigkeit zur Freigabe	Freigegeben
Selbstschließung	C
Dauerhaftigkeit der Fähigkeit zur Freigabe	Freigabe aufrechterhalten
Dauerhaftigkeit der Selbstschließung - gegenüber Qualitätsverlust (Dauerfunktion) - gegenüber Alterung (Korrosion)	2 (erzielt)

Die Leistung des Produkts gemäß den Nummern 1 entspricht der erklärten Leistung nach Nummer 6. Verantwortlich für die Erstellung dieser Leistungserklärung ist allein der Hersteller gemäß Nummer 3.

* Die maximale lichte Öffnung gilt nur für EI 60 ohne Rauchschutz. Für Systeme mit Sa oder S200 ist die lichte Öffnung eingeschränkt. Siehe dazu die Vorgaben auf Seite 3.



Notified Body No. 2434

Centrum Techniki Okrętowej S.A.
Product Certification Division
Szczecińska 65, 80-392 Gdańsk, Poland
phone: +48 58 307 45 28
e-mail: certyfikacja@cto.gda.pl

CENTRUM TECHNIKI OKRĘTOWEJ S.A.
PRODUCT CERTIFICATION DIVISION



AC 170

CERTIFICATE OF CONSTANCY OF PERFORMANCE

2434-CPR-0110

In compliance with Regulation(EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction products Regulation or CPR) as amended, this Certificate applies to the construction product:

Fire resistant and smoke control rolling shutter, type Fire PROtec-EI MARC

in fire resistance class, acc. to PN-EN 13501-2:2016

EI₁₄₅, EI₁₂₀, EW₁₂₀

in smoke control classes, acc. to PN-EN 13501-2:2016

S_a, S₂₀₀

placed on the market under the name or trade mark of :

SIMON PROtec Systems GmbH
Medienstrasse 8
94036 Passau, Germany

and produced in the manufacturing plant:

616-001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

The product is also covered by EN 13241:2003+A2:2016 standard as part of system 3 of assessment and verification of constancy of performance.

This certificate was first issued on 17.04.2020, was amended on 09.03.2022 and will remain valid as long as neither the harmonised standard, the construction product, the assessment and verification of constancy of performance methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

Zuzanna Andrzejewska
Zuzanna Andrzejewska

Head of the Product Certification Division of CTO S.A.

Gdańsk, 09.03.2022

Page: 1/2

Essential characteristics	Requirements of EN 16034:2014 standard	Level, class and/or description
Resistance to fire	4.1	EI₁₄₅, EI₂₆₀, EW₁₂₀
Smoke control	4.2	S _a , S ₂₀₀
Ability to release	4.3	released
Self-closing	4.4	C
Durability to ability to release	4.5.1	release maintained
Durability of self-closing against degradation	4.5.2.1	category of use 2
Durability of self-closing against ageing (corrosion)	4.5.2.2	achieved

The performance characteristics, resulting from EN 13241:2003+A2:2016 harmonised standard, which are subject of the system of assessment and verification of constancy of performance 3, shall be obtained from the product manufacturer's declaration of performance.

Product description:

A fire resistant rolling shutter of Fire PROtec-EI MARC **EI₁₄₅/EI₂₆₀/EW₁₂₀** type with maximum dimensions: width 16 m, height 10 m, consists of the following elements: a rolling shutter jacket, a winding shaft, winding shaft supports, guides, a load of the bottom edge, a drive system.

A fire resistant and smoke control rolling shutter with maximum dimensions:

- 2 x high + width ≤ 14,68 m (in the clear of the frame), (S_a, pressure 10 Pa),

-2 x high + width ≤ 9,27 m (in the clear of the frame), (S_a, pressure 25 Pa),

-width 2850mm, height 2325 mm (S₂₀₀, pressure 10, 25 and 50 Pa)

The rolling shutter jacket consists of three layers, including two identical external layers (FM1D) and an internal layer (MH-6). The particular parts of the materials are sewn together with Dg thread.

The upper edge of the rolling shutter jacket is attached to the winding shaft, made of a steel tube through a steel flat bar. The external layers of the jacket, along its lower edge, are connected with each other with MARTEX-00/MARC-00 material, to each of the external layer a load of the rolling shutter lower edge made of steel flat bar is mounted. The guides are made of galvanised steel sheet and protected with fire-resistant plates.

The rolling shutter opening is driven by a tubular motor or an external driving system.

The rolling shutter control is provided by a control centre.

Detailed technical parameters and final classification conditions, acc. to PN-EN 13501-2:2016 standard, are provided in Classification Report No. LBO-905-K/19 of 05th September 2019 and LBO-126-KD/21 of 19th August 2021.

Assembly:

A standard rigid fixing structure of high or low density.

Intended use:

To be used as a vertical, mobile partition to close the passage between fire separation zones at industrial premises and public buildings.